



नवी मुंबई महानगरपालिका

Navi Mumbai Municipal Corporation

मुख्यालय से.15 ए, किल्ले गावठाण जवळ,
सी.बी.डी. बेलापूर, नवी मुंबई - 400 614
दुरध्वनी क्रमांक: 2756 7070, 2756 5700

Head Quarter, Sec.15A, Near kille Gaonthan,
CBD., Navi Mumbai- 400 614
TEL.No. :2756 7070, 2756 5700

No.NMMC/SWM/1063/2023.

Date :- 9/10/2023.

To WHOMSOEVER IT MAY CONCERN

This is to certify the Navi Mumbai Municipal Corporation's Sanitary officer has inspected at MAHATMA GANDHI MISSION Primary & Secondary School, Plot no.14, Sector-8, Phase-II Nerul Navi Mumbai-400706. On dated.13.10.2023 from the sanitary point of view. The aforesaid premise is found to be satisfactory and hence this certificate is signed and issued for office use only.

This Certificate is issued as per Principal, MAHATMA GANDHI MISSION Primary & Secondary school request letter.

Rajale
18/10

(Babasaheb Rajale)

**Dy.Municipal Commissioner
Solid Waste Management Dept.
Navi Mumbai Municipal Corporation**

To
MAHATMA GANDHI MISSION
Primary & Secondary School,
Plot no.14, Sector-8, Phase-II
Nerul Navi Mumbai-400706



नवी मुंबई महानगरपालिका

Navi Mumbai
Municipal Corporation

पर्यावरण प्रयोगशाळा
अग्रोळी पुलाखाली, सी.बी.डी. बेलापूर, नवी मुंबई 400 614.
दुरध्वनी क्र. : 2757 9882



NMMC/Environment Laboratory/73/2023-2024

Date : 27/09/2023

Date of sample received. : 27/09/2023

Date of sample testing : 27/09/2023 to 03/10/2023

Customer's Name and Location : Mahatma Gandhi Mission
Primary & Secondary School
Sector - 8, Phase II
Nerul Navi Mumbai 400 706

Samples : - 1) Ground Floor
2) First Floor
3) Second Floor

TEST REPORT


	Testing Parameter	pH	Turbidity	Residual Chlorine	Total Coliforms	E. Coli	F. Coli
Sr. No.	Test Standards (IS 10500 : 2012)	6.5 - 8.5	Max. 5.0 N.T.U.	Min. 0.2 mg/l	0 per 100 ml	-ve	-ve
1)	Ground Floor	6.9	0.0	0.1	0	- ve	- ve
2)	First Floor	6.9	0.0	0.1	0	- ve	- ve
3)	Second Floor	6.9	0.0	0.1	0	- ve	- ve

Test Report No. : 73

Date : 03/10/2023

Conclusion : Test results of the sample are based on the sample submitted in the laboratory.

Lab Incharge


Lab Chemist


Environment Laboratory
Navi Mumbai Municipal Corporation